

**SODIUM HYPOCHLORITE FOR THE FISCAL YEAR**  
**JUNE 1, 2021 TO MAY 31, 2022**

**DATE:** March 17, 2021

To Whom It May Concern:

Notice is hereby given that sealed proposals are sought and requested for the following:

**BID OPENING INFORMATION**

**NAME:** Sodium Hypochlorite  
**DATE:** **April 8, 2021**  
**TIME:** **2:00 PM**  
**PLACE:** Village of Malone, 343 West Main Street, Malone, NY

**BID PROCEDURE INFORMATION**

Bids shall be submitted in sealed envelopes addressed to:  
Village of Malone  
343 West Main Street  
Malone, NY 12953

On the face of said envelope the following shall be included:

- 1) NAME AND ADDRESS OF BIDDER
- 2) NAME OF BID: SODIUM HYPOCHLORITE

**NOTE: BIDDERS ARE ADVISED NOT TO RELY ON NEXT DAY MAIL OR DELIVERY SERVICES. BIDS MUST BE IN THE CLERK'S OFFICE ON THE DAY, DATE AND TIME SPECIFIED.**

No contractor/vendor to whom this contract is let, granted or awarded shall assign, transfer, any interest herein, including the performance of this contract or the right to receive monies due to or to become due, or of his power to execute this without the proper written consent of the Malone Village Mayor. In the event that the contractor shall without prior written consent assign, transfer, convey, sublet or otherwise dispose of this contract or of his right, title and interest herein, including the performance of this contract, or the right to receive moneys due or become due, or his power to execute such contract onto any other person or corporations, or upon receipt by the Village of Malone of an attachment against the contractor, the Village shall be relieved and discharged from any and all liability and obligation growing out of such contract shall have been assigned, his assignees, transferee or sublease shall forfeit and lose all monies theretofore earned under this contract, except so much as may be required to pay his employees.

Each bid should contain a non-collusion statement as required by Section 103D of the General Municipal Law of the State of New York and an Iran Divestment Act Affidavit as required by General Municipal Law 103G of the State of New York.

The Village reserves the right to reject any or all bids.

Rebahka Scaccia, Village Clerk

**Fiscal Year 2021-2022**

**SCOPE:** Village of Malone invites sealed bids for the purchase of Sodium Hypochlorite – Potable Water Plant.

Specifications are as follows:

The Village of Malone will use a 15% trade solution on a year-round basis.

Delivery time following the receipt of the order must be within 4 days. Delivery will be at the Water Treatment Plant at 192 County Route 25, Malone NY 12953. Delivery time will be between the hours of 7:00 AM and 1:00 PM, Monday-Friday. All prices will include freight and surcharges.

Bidders must specify the unit weight of 15% sodium hypochlorite trade solution in pounds per gallon on the bid schedule and submit appropriate emergency service phone numbers, technical storage and handling information and current Material Safety Data Sheets (MSDS) with NFPA ratings.

The Village retains the right to terminate the contract at any time if it is deemed that the 15% sodium hypochlorite trade solution is incompatible with the pumping equipment, material, or it does not meet criteria set forth regarding minimum solution strength or having mercury levels higher than what is listed in this specification (0.15 mg/l).

**Estimated Quantities**

All quantities are estimates and actual amounts may vary.

4,500 gallons in 55-gallon drum containers.

Bidder must supply a MSDS with the Bid Proposal and the MSDS must include NFPA ratings for 15% sodium hypochlorite trade solution. The NFPA ratings shall include health hazard, fire hazard and reactivity. Additionally, any specific hazard information must be included which needs to be displayed. For all the hazards, a numerical rating must be given for the NFPA rating. All chemicals must meet or exceed the AWWA Standard for use in water supplies. All chemicals must also be NSF approved.

**AWARD:**

Bid Award will be made to the Lowest Responsible Responsive Bidder.